

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Armstrong Flooring, Inc.

Rt 250 South, P.O. Box 160, Beverly, WV 26253; 508 Thornburg, Box 929, West Plains, MO 65775; 688 Highway 278 Bypass, Warren, AR 71671

For the following product(s):

Solid Hardwood:

All Armstrong® Solid Wood Flooring, Bruce® Solid Wood Flooring and Capella®

Solid Wood Flooring

Maximum thickness 19mm

The product(s) meets all of the necessary qualifications to be certified for the following claim:

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-04650

Valid from: September 1, 2018 to August 31, 2019

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065
Product Certification Body
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA